


NOTES

1. To be used only for repairs or reinstatements to existing kerbs. New Works shall use VicRoads standard drawing.
2. \*Tray width may be reduced to match existing conditions.
3. When placed by hand, all concrete shall be compacted with the aid of immersion vibrators or other vibrating equipment as approved by the superintendent.
4. Concrete shall be 25 MPa minimum.

	City of Whittlesea	
	BARRIER KERB & CHANNEL 600mm WIDTH	SD 301
APPROVED <i>Neil Hooley</i>	DATE 01/03/06	REV B